44658

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

14969

OWNER OR CONTRACTOR Donnie Sherrill DATE 9/3/92 PERMIT NO. 90-9-A-60

PHONE: Business _____ Home _____

LOCATION NC 90W TR LITTLE FARM ROAD, TL Jo MONNIE ACRES, BEYOND 3RD (H) ON (L) S.R. No. _____

SUBDIVISION NAME Jo MONNI ACRES LOT NO. _____ SECTION OR BLOCK NO. _____

House ☐ Mobile Home ☑ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 4.83Ac

Soil Characteristics PS


Application Rate 0.40 GPD / FT²

Topography 2-4% LS

Depth to Water Table 34'

Rock or other impervious formations NONE

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ☑ WELL NEXT DOOR

Public ☐

Installed by A-1 BACKHOE

I understand and agree to install a septic tank system as specified on this Improvement Permit.

AMANDA LANE

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY STEVE HEDRICK

COMMENTS ① REPAIR AREA IS 100% CONVENTIONAL GRAVITY-FED

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 9/3/92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit. Jo MONNI ACRES DRIVE

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold