Flake Pratt Bldr.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mickey Sharpe DATE 6-1-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 90 To Toney. T.R. on Rd 1548 - T.L. into Jo Moni Acres on Rd. 1653 S. R. No. _____

SUBDIVISION NAME Jo Moni Acres LOT NO. _____ SECTION OR BLOCK NO. _____

House (+) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (+)	
Auto. Dishwasher	Yes (+)	No ( )	
Auto. Wash. Machine	Yes (+)	No ( )	
Site Suitable	Yes (+)	No ( )	

Lot Area 20,000 sq ft


Character & Porosity of Soil Red Clay

Percolation Rate _____

Topography Slope

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (+)

Installed by Hoke Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: All surface water possible should be diverted away from Tank & lines

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6-1-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold