C. R. Little Property

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Janice Fleishman DATE 8-28-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 90 To Long. T.R. on Rd 1548 - Trailer back off of Rd. Just beyond Jo Moni Acres. on L S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 9 acres


Character & Porosity of Soil Red Clay

Percolation Rate _____

Topography Slight Slope

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

From Fathers House

Installed by Raymond Johnson

IMPROVEMENTS PERMIT BY Rd 1548 →

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 8-29-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold