EPARTMENT OF ENVIRONMENT,
EALTH, & NATURAL RESOURCES
VISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 4716 73 6429
PROPERTY RECORDED:
COUNTY: IREDELL

# SOIL/SITE EVALUATION
## FOR
## ON-SITE WASTEWATER SYSTEM

PPLICANT: CRANDALL & O'BRIEN CONST OWNER: AGENT: PHONE: 871-1536
DDRESS: 310 TREEBARK ROAD APPLICATION DATE: DATE EVALUATED: 5-28-98
STATESVILLE, NC PROPOSED FACILITY: 3BR House W C.S.
28625 PROPERTY SIZE: 0.425 ACRE
OCATION OF SITE: SUMMERSET S/D LOT # 20
ATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

| PROFILE # | .1940 LANDSCP POS. (%) | HORIZON DEPTH (IN.) | .1941 STRUCTURE/TEXTURE | .1941 MINERALOGY/ CONSISTENCE | .1942 WETNESS COND. | .1944 RESTRICT HORIZONS | .1948 CLASS OF HORIZ | 1943/ 1956 SAPRLT CLASS. | HORIZON LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | L 2-6% | 0-9 | MMSBK / CL | 1:1 / FR/S | - | - | PS | - | 0.3 |
| | | 9-31 | MMSBK / C | 1:1 / FR-FI | | | | | |
| | | 31-48 | WMABK / SiCL | 1:1 / FR | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 2 | L 2-6% | 0-8 | MMSBK / CL | 1:1 / FR-S | - | - | PS | - | 0.3 |
| | | 8-30 | MMSBK / C | 1:1 / FR-FI | | | | | |
| | | 30-98 | WMABK/SiCL | 1:1 / FR | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 3 | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 4 | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 5 | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

VAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.3 GPD/FT²
VALUATED BY: S. HERRICK OTHER(S) PRESENT: TERRY O'BRIEN DICK CRANDALL
OMMENTS: EXISTING DRAINAGE DITCH LIMITS AVAILABLE SPACE