IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tommy C. Woodfin DATE 6/30/75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy #90 W To Loray, T.R. on Rd #1548 - cross stream - mobile homes on Rt across from Jr - Moni Acres

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area _____

Character & Porosity of Soil Red Clay loam


Percolation Rate ran

Topography Slope to rear

Depth to Water Table sat

Rock or other impervious formations none observed

Existing System



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines —

Sq. Ft. — Linear Ft. 400

Depth of Stone in Lines —

Water Supply: Individual ( )

Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Original system put in on 12/1/72 under Mack Little

Mack Little's property

System originally designed for two mobile homes

CERTIFICATE OF COMPLETION BY Andrew L. Causey DATE 6/30/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold