DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ *of* ____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Tim Johnson / Brad Johnson
ADDRESS:
PROPOSED FACILITY: 3 BR Home
LOCATION OF SITE: midway Rd. beside Victory Bapt. Church
PROPOSED DESIGN FLOW (.1949): 360 gal.
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

APPLICATION DATE _____
DATE EVALUATED: _____
PROPERTY SIZE: _____
PROPERTY RECORDED: _____

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 4%	0-12	vfSK/SL	fr/SoPo	7.18	7.18	-	-	PS 0.3
		12-48+	SSK/C	fr-fi/SoPo					
2	L/SL	0-6	vfSK/SL	fr/SoPo	7.18	7.18	-	-	PS 0.3
		6-48+	SSK/C	fi/SoPo					
3	L/H	0-8	vfSK/SCL	fr/SoPo	7.18	7.18	-	-	PS 0.3
		8-48+	SSK/C	fi/SoPo					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	III
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: TCH
OTHER(S) PRESENT: Tim Johnson, Brad Johnson

COMMENTS: