P.L. 439.58'

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 072024 PIN# 4717 13 7410 (PT) DATE 3-9-98

OWNER OR CONTRACTOR RODNEY FORBES PHONE: Business 872-8974 Home 876-2980

ADDRESS 384 COOPER FARM ROAD, STATESVILLE NC 28625

LOCATION NC 115 N, TL MIDWAY ROAD, TR BAUER ROAD, 4TH LOT ON LEFT

SUBDIVISION _____ BLOCK / SECTION _____ LOT _____ LOT AREA 4 ACRES SITE CLASS: P3 DESIGN FLOW 360 L.T.A.R. 0.30 GPD/FT²

Septic Tank: 1000 Gallons; STB 1007 Date 9-18-01
Pump Tank: _____ Gallons; PT _____ Date _____
Pump Make: _____ Model _____ Serial No. _____
Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400
No Lines FOUR Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12"

☑ New System ☐ Repair System Type: ☐ I ☐ II, IV, V, VI
System Description: CONVENTIONAL GRAVITY
Repair System Description: CONV. GRAVITY
Maintenance Agreement Required: ☐ Yes ☑ No
☐ Slab ☑ Crawl Space ☑ Basement w/plumbing ☐ Basement wo/plumbing

☑ House/Mod. Home No. Bedrooms 3
☐ Mobile Home No. Bathrooms 2½
☐ Business No. Employees _____
☐ Other _____

Water Supply: ☑ Individual ☐ Public ☐ Community
WELL

Comments:/Conditions: KEEP SYSTEM MINIMUM 100' FROM WELL

Comments:/Conditions: SEPTIC TANK WITH MARKER INSTALLED USING "ZABEL" FILTER @ LINES INSTALLED ON CONTOUR AS SHOWN BELOW.

REPAIR AREA

INITIAL SITE SKETCH

SCALE: 1"=60'

3'x100'
3'x100'
3'x100'
3'x100'

DROP BOXES

SEPTIC TANK

46'

60'

POTENTIAL WELL SITE

90.5'

HOUSE

70'

210'

DRIVEWAY

PROPOSED LINE 400.9'

29 30 31 32

P.L. 440.02' (TOTAL)

BAUER DRIVE (60' R/W)

AS BUILT SKETCH

3'x100'
3'x100'
3'x100'
3'x100'

DROP BOXES (4)

SEPTIC TANK

HOUSE

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Rodney J Forbes

Improvement Permit by: STEVE HEDRICK date 3-9-98

Authorization to Construct by: STEVE HEDRICK date 3-9-98

Installed by: A&C GRADING

Operation Permit by: STEVE HEDRICK date 10-25-01

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD