HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 99-A-38
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: DAVID SHANGLE OWNER: AGENT: ✓ PHONE: 872-1388
ADDRESS: RT. 8, BOX 89-A APPLICATION DATE: 5/16/94 DATE EVALUATED: 5/16/94
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: ~ 1/2 ACRE
LOCATION OF SITE: NC 115 N, TL MIDWAY ROAD, TR PRIVATE DRIVE #325 JUST PAST MIDWAY MHP
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ~~✓~~ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	L 8%	0-48	C	SBK	1:1 / FI	.1942 WETNES CONDITION	S
						.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35
2	L 8%	0-48	C	SBK	1:1 / FI	.1942 WETNES CONDITION	S
						.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35
3						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

BACK OFF ROAD ~ (R)

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: MICHAEL MAFFUCCI
COMMENTS:

DRAFT