IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

9852

OWNER OR CONTRACTOR Farly Hager DATE 9-6-89 PERMIT NO. 410

PHONE: Business _____ Home _____

LOCATION Hwy 21 Midway Rd past Bright Light Church on Left

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 3 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 20,000

Character & Porosity of Soil Gray Suitable
Percolation Rate 24 Min
Topography Slight
Depth to Water Table 36"+
Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 300 Linear Ft. 200
Depth of Stone in Lines 18"
Water Supply: Individual ( )
Public (✓) Comm. Well

Installed by Wayne Jones

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 9-6-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold