IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 068606 DATE 7-29-97 TAX MAP NO. 4717215935 Watershed: ☐ Yes ☒ No

OWNER OR CONTRACTOR EARLIE & FAYE NAGER PHONE: Business Home 876-3154

ADDRESS 524 COVE GAP ROAD, STATESVILLE, NC 28677

LOCATION NC 115 N, TL MIDWAY ROAD, TL STANLEY, TR KITE LANE, LOT AT END ON LEFT

SUBDIVISION ____ BLOCK / SECTION ____ LOT 4 LOT AREA LMI SITE CLASS. PS DESIGN FLOW 240 L.T.A.R. EXISTING

Septic Tank: 1000 Gallons; STB ____ Date ____

Pump Tank: ____ Gallons; PT ____ Date ____

Pump Make: ____ Model ____ Serial No. ____

Nitrification Field: No Fields 1 Square Feet 720 Linear Feet 240

No Lines THREE Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12"

☐ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: CONV. GRAVITY

Repair System Description: ____

Maintenance Agreement Required: ☐ Yes ☒ No

☐ House/Mod. Home No. Bedrooms 2

☒ Mobile Home No. Bathrooms 2

☐ Business No. Employees ____

☐ Other ____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Community ☐ Public

Comments:

Comments: KEEP SYSTEM MINIMUM 5' FROM MH.

INITIAL SITE SKETCH

KITE LANE

AS BUILT SKETCH

S/W MH

DRIVEWAY

3'x80'

3'x80'

3'x80'

3'

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance. ~~AUTHORIZATION TO CONSTRUCT IS VALID FOR 60 MONTHS~~ ~~IT~~

Signed: ____ Installed by: ____

Improvement Permit by: ____ date ____ ~~Certificate of Completion~~ by: ____ date ____

Existing System Inspection by: STEVE HENDRICK date 7-29-97 Operation Permit by: ____ date ____

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD