10172.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR EARLIE HAGER DATE 11-3-89 PERMIT NO. A10

PHONE: Business _____ Home _____

LOCATION Hwy 115N - Gl. on Midway Drive - go 2 miles past Bristol Light Church on left

SUBDIVISION NAME MIDWAY PARK S. R/W No. _____

LOT NO. 6 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 100' x 200'

Character & Porosity of Soil Sandy Loam Suitable


Percolation Rate Good

Topography Level

Depth to Water Table 12+

Rock or other impervious formations Not encountered.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 24

Water Supply: Individual ( )

Public (✓)

Installed by Cliffside Farms

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY: Darren Meaver

COMMENTS: _____

CERTIFICATE OF COMPLETION BY: Steve Brown DATE 11-3-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Contractor's Copy: Pink Owner's Copy: Gold