SHEET 1 OF 1

DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: 9K - A - 77 (PART OF)
DATE: 6/16/95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: EARLIE C. HAGER
OWNER ✓ AGENT: PHONE: 876-3159
ADDRESS: Rt 8, Box 69, STATESVILLE, NC 28677
APPLICATION DATE: 1/11/95 DATE EVALUATED 1/ /95
PROPOSED FACILITY: 3 BR S/W MH
PROPERTY SIZE: 100'x155'
LOCATION OF SITE: MIDWAY ROAD MHP SECTION II LOT # 25
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN.)	.1941 [1][1] TEXTURE	.1941 [1][2] STRUCTURE	.1941 [1][3] MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
	L	0-48	C	SBK	1:1/FI			.1942 Wetness Cond. S.
	7%							.1943 Depth/.1956 Sapr. S.
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3 GPD/FT²
2								.1942 Wetness Cond.
								.1943 Depth/.1956 Sapr.
								.1944 Restrictive Hori.
								.1948 Profile Class.
								Profile LTAR
3								.1942 Wetness Cond.
								.1943 Depth/.1956 Sapr.
								.1944 Restrictive Hori.
								.1948 Profile Class.
								Profile LTAR
4								.1942 Wetness Cond.
								.1943 Depth/.1956 Sapr.
								.1944 Restrictive Hori.
								.1948 Profile Class.
								Profile LTAR

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE CONVENTIONAL GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.3 GPD/FT²

EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: RHYNE BYERS

COMMENTS:

00475