DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 9K - A - 77 (PART OF)
DATE: 6/16/95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: EARLIE C. HAGER
OWNER ✓ AGENT: PHONE 876-3159
ADDRESS: Rt. 8, Box 69, Statesville, NC 28677
APPLICATION DATE 1/11/95 DATE EVALUATED 1/ /95
PROPOSED FACILITY: 3 BR S/W MH
PROPERTY SIZE: 100 x 155
LOCATION OF SITE: MIDWAY ROAD MHP SECTION II LOT # 26
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (1)(1) TEXTURE	.1941 (1)(2) STRUCTURE	.1941 (1)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	L	0-48	C	SBK	1:1/FI			.1942 Wetness Cond. 5
	4%							.1943 Depth/.1956 Sapr. 5
								.1944 Restrictive Hori. 5
								.1948 Profile Class. PS
								Profile LTAR 0.3
2								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) 5 OTHER FACTORS (.1946) NONE SITECLASSIFICATION (.1948) PS
SYSTEM TYPE CONVENTIONAL GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.3 GPD/FT²
EVALUATED BY: STEVE HENDRICK OTHER(S) PRESENT: RHYNE BYERS/EARLIE HAGER
COMMENTS: