DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 9K-A-77 (PART OF)
DATE:
COUNTY: IREDELL

# SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: EARLIE C. HAGER
ADDRESS: RT 8, Box 69 STATESVILLE, NC 28677
OWNER ✓ AGENT: PHONE 876-3159
APPLICATION DATE: 1/11/95 DATE EVALUATED 5/26/95
PROPOSED FACILITY: 3 BR S/W MH
PROPERTY SIZE: LIMITED
LOCATION OF SITE: MIDWAY ROAD MHP SECTION II LOT # 33/34 COMBINED
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

| PROFILE # | .1940 LANDSCP POS / SLOPE(%) | HORIZON DEPTH (IN.) | .1941 (1)TEXTURE | (2) STRUCTURE | (3) MINERALOGY | MATRIX COLOR | MOTTLE COLOR | OTHER PROFILE FACTORS |
|---|---|---|---|---|---|---|---|---|
| 1 | L | 0-48 | C | SBK | 1:1 / FI | | | .1942 Wetness Cond. - 5 |
| | 10% | | | | | | | .1943 Depth/.1956 Sapr. - 5 |
| | | | | | | | | .1944 Restrictive Hori. - 5 |
| | | | | | | | | .1948 Profile Class. - PS |
| | | | | | | | | Profile LTAR 0.3 |
| 2 | N | 0-48 | C | SBK | 1:1 / FI | | | .1942 Wetness Cond. - 5 |
| | 8% | | | | | | | .1943 Depth/.1956 Sapr. - 5 |
| | | | | | | | | .1944 Restrictive Hori. - 5 |
| | | | | | | | | .1948 Profile Class. - PS |
| | | | | | | | | Profile LTAR - 0.3 |
| 3 | | | | | | | | .1942 Wetness Cond. - |
| | | | | | | | | .1943 Depth/.1956 Sapr. - |
| | | | | | | | | .1944 Restrictive Hori. - |
| | | | | | | | | .1948 Profile Class. - |
| | | | | | | | | Profile LTAR - |
| 4 | | | | | | | | .1942 Wetness Cond. - |
| | | | | | | | | .1943 Depth/.1956 Sapr. - |
| | | | | | | | | .1944 Restrictive Hori. - |
| | | | | | | | | 1948 Profile Class. - |
| | | | | | | | | Profile LTAR - |

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITECLASSIFICATION (.1948) PS

SYSTEM TYPE CONVENTIONAL GRAVITY LONG-TERMACCEPTANCE RATE(S) 0.3

EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: PAYNE BYERS

COMMENTS: LOTS 33 & 34 COMBINED DUE TO SPACE AVAILABLE & EXISTING GULLIES

0045