EALTH, & NATURAL RESOURCES
IVISION OF ENVIRONMENTAL HEALTH
N-SITE WASTEWATER SECTION

PROPERTY I.D.#: 9P-A-46
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RITA BARRINGER OWNER: ✓ AGENT: PHONE: 592-4865
ADDRESS: P.O. BOX 147 APPLICATION DATE: 9/14/99 DATE EVALUATED: 9/14/99
UNION GROVE, NC 28689 PROPOSED FACILITY: 3 BR MH
PROPERTY SIZE: ACREAGE
LOCATION OF SITE: NC 115 N, TL MIDWAY RD, TR COVE GAP RD, 2ND DRIVE ON (L)
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 10-15%	0-28	C	ABK	1:1 / FI	.1942 WETNES CONDITION S
		28-48	SC/SCP	SBK	1:1 / FR	.1943/.1956 SAPROLITE PS
						1944 RESTRICTIVE HORIZON S
						1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
2	H 10-12%	0-24	C	ABK	1:1 / FI	.1942 WETNES CONDITION S
		24-48	SC/SCP	SBK	1:1 / FR	.1943/.1956 SAPROLITE PS
						1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: JONATHON & RITA BARRINGER & NEECE, WAUGH TWINS
COMMENTS:

DRAFT