DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Tim Hamby Statesville APPLICANT: Tim Hamby
ADDRESS: 906 Old Mocksville Rd, APPLICATION DATE: _____ DATE EVALUATED: 2/11/02
PROPOSED FACILITY: 3BR Home PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.18 Ac
LOCATION OF SITE: _____ PROPERTY RECORDED: Yes
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Lot # 17 Mountain View

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	5% Linear	0-10"	scl sbk	fr ss sp SEXP	YBR BM				PS .3
		10-48	sc mbk	fi ss sp SEXP					
2	5% Linear	0-11"	scl sbk	fr ss sp SEXP	DRa BM				PS .3
		11-48"	sc mbk	fi ss sp SEXP	Red BM				
3	5% Linear	0-12	scl sbk	fr ss sp SEXP	DRa BM				PS .3
		12-48	cc mbk	fi ss sp SEXP	Red BM				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity Conv	Gravity 25% Red
Site LTAR	.30	.30

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: Tim + Teresa Hamby