DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet
PROPERTY ID #
COUN

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Tim Hamby APPLICANT: Same
ADDRESS: APPLICATION DATE: DATE EVALUATED: 6/14/01
PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: 1.03
LOCATION OF SITE: PROPERTY RECORDED:
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Lot #40 Mtn View Estates

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	5% Linear	0-6	scl	fr					PS .3
		6-38	cl m sbk	fi/fr ss sp SEXP					
		38-48	scl/sap w sbk	ss sp SEXP					
2	3% Linear	0-8	scl	fr NS,WP MEXP					PS .3
		8-34	cl m sbk	fi/fr ss sp SEXP					
		34-48	scl/sap fg sbk sap bmx w sbk	fi/fr ss sp SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity, Conv.	Gravity, 25% Reduction
Site LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: