DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: American Legion APPLICANT: A.H. Inc.
ADDRESS: Charlotte, N.C. 28215 APPLICATION DATE: 3-29-01 DATE EVALUATED: 4/24/01
PROPOSED FACILITY: 30R Hwy/SR 6 PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .99 Ac
LOCATION OF SITE: PROPERTY RECORDED: Yes
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 2%	0-13	SCL w lst	Fr SS SPSE	20" FC				PS -3
		13-41	cc w/ some mica	Fi S P SPSE					
2	L 2%	0-14	See		26" BRN/GY				PS -3
		14-37	2C some	Fi S P SPSE					
		37-48	2C/SCL some	F SPSE					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	P.S.	P.S.
System Type(s)	25% Red Conv	50% Red Conv
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): Bill Johnson
EVALUATED BY: _____
OTHER(S) PRESENT: _____