DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: George Hensley APPLICANT: Same
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 2/26/02
PROPOSED FACILITY: 3BR House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.75Ac
LOCATION OF SITE: _____ PROPERTY RECORDED: yes
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

Mtn. View # 38

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	Linear	0-6	scl	fr SS sp SEPP					PS .3
		6-49	cl some mica Sbk	fi/th SS sp SEPP					
2	Linear	0-7	scl	fr SS sp SEPP					PS .3
		7-49	cl some mica Sbk	fi/fi SS sp SEPP					
3	Linear Repair	0-9	scl	fi SS sp SEPP					PS .3
		9-49	cl some mica Sbk	fi/fi SS sp SEPP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Trench Conv.	Trench Conv.
Site LTAR	.30	.30

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____