IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hassill Reep DATE 11-30-84 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N TL on Pisgah Ch Rd Then TL on Liberty Hill Rd 1/4 mi on left.

SUBDIVISION NAME _____ LOT NO. _____ S. R. No. _____

SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Adding new system for existing house

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Clayey
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate .4 Sal/Sq/Day
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2 to 6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 10'+
			Rock or other impervious formations Saprolite At 36 to 48"

Lot Area acreage

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 11-30-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold