IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

DATE 10 11 88 PERMIT NO. C6

OWNER OR CONTRACTOR 9053 David E Douglas

PHONE: Business _____ Home _____

LOCATION Hwy 115 & Eagle 2mi N on paved drive S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay Suitable

Percolation Rate 1"

Topography Hilly

Depth to Water Table 10 ft

Rock or other impervious formations None

Lot Area 1 Acre

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

Size of Tank 1000 Gals.

Nitrification Field:


No. of Lines 3

Sq. Ft. 900 Linear Ft. 500

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )



Plot of System

Installed by A J Backhus

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Johnson

COMMENTS: _____

DATE 10/11/88

CERTIFICATE OF COMPLETION BY Johnson DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold