IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Glen Harbin Jr. DATE July 22, 1977 PERMIT NO. _____

PHONE: Business _____ Home 872-6524

LOCATION 115 N T.L. on Pisgah Ch. Rd. go 1.9 mi. T.L. on paved private rd. 1st dirt rd. to rt. at end on left. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 400'x200' approx.

Character & Porosity of Soil Cecil clay loam
Percolation Rate _____
Topography 2%
Depth to Water Table unk.
Rock or other impervious formations none observed



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10" +
Water Supply: Individual (✓)
Public ( )

Installed by James Hartness

IMPROVEMENTS PERMIT BY Andrew E. Causey

COMMENTS: 7½'x84' bed w/ 3 lines used.

CERTIFICATE OF COMPLETION BY David R. Hinson DATE July 22, 1977

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold