IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 158116 PIN # 4718265340 DATE 9-18-09

OWNER or APPLICANT NELSON DELLINGER RIDGE CO PHONE: Business 7049020429 Home: 7048764387

OWNER or APPLICANT ADDRESS 170 Pisgah Church Rd Statesville NC 28625

LOCATION / DIRECTIONS 115 North (L) Pisgah (R) Dickson (R) Harbin on RT second LOT

SUBDIVISION Pisgah SUBDIVISION BLOCK / SECTION LOT # 12 LOT AREA 1.46 DESIGN FLOW 360 L.T.A.R. .25

Septic Tank 1000 Gallons: STB 1017 Date 5-5-09

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 6 Linear Feet 240'

Trench Width 24" Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: GRAVITY 50% REDUCT

Repair System Description: MAX FEASIBLE

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 3 ☐ Business No. Persons ☐ Other No. Employees ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions (1) Install 6 lines 40' long as flagged. (2) Use 1 Flow Divider tee & 2 distribution devices such as Zoeller true flow splitter or distribution boxes with speed levelers. (3) Horz. system, pt 15 - are flagged at

Comments / Conditions completely. (4) Install lines on contour as flagged & maintain setbacks.

INITIAL SITE SKETCH

SEE System Design Attachment By LORNE COOK, R.S.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 9-21-09

Improvement Permit by: Date 9-18-09

Authorization to Construct by: Date 9-18-09

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Tommy Fagg

Operation Permit by: Date: 11-3-09

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant

1" = 30

Permit # 158116

Pin # 4718265340

Attachment 1

