EPARTMENT OF ENVIRONMENT,
EALTH, & NATURAL RESOURCES
VISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 4718 75 6235
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

PPLICANT: R. B. COMPTON OWNER: ✓ AGENT: PHONE: 876-2694
DDRESS: 339 PISGAH CH. RD APPLICATION DATE: DATE EVALUATED: 5-31-98
STVL, NC 28677 PROPOSED FACILITY: 3BR A/W MH
PROPERTY SIZE: 26.06 ACRES
CATION OF SITE: NC 115 N TL PISGAH, 0.9 MILE ON RIGHT
ATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	L 4%	0-48	SBK / SC	1:1 / FR	—	—	PS	—	0.4
2	L 3%	0-48	SBK / SC	1:1 / FR	—	—	PS	—	0.4
3									
4									
5									

VAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.4 GPD/FT2
VALUATED BY: S. HENDRICK OTHER(S) PRESENT: R. B. COMPTON & WIFE
OMMENTS: