IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

10623

OWNER OR CONTRACTOR Gene Hall

PHONE: Business _____ Home _____ DATE 10-27-89 PERMIT NO. NB-A-4601

LOCATION 115 N to Pisgah Church Rd Turn on drive 1st 3rd dwelling on Left

SUBDIVISION NAME _____ LOT NO. _____ S. R. No. _____


House (X) Mobile Home ( ) Business ( ) Other _____ SECTION OR BLOCK NO. _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes (X) No ( )
Auto. Wash. Machine Yes (X) No ( )
Site Suitable Yes (X) No ( )
Lot Area 5 Ac

Character & Porosity of Soil Loam Suitable
Percolation Rate Slow
Topography Slight
Depth to Water Table 60"+
Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 450 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by James Hall

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY D Allen

COMMENTS: Use diagram dwg 58

CERTIFICATE OF COMPLETION BY D Allen DATE 10-27-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold