IREDELL COUNTY HEALTH DEPARTMENT

*THIS PERMIT REPLACES VOIDED PERMIT UNDER # 113863 DATED 9-30-03

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 113863 PIN# 4718-92-4976 DATE 3-16-04

OWNER OR CONTRACTOR TERRY O'BRIEN PHONE: Business 704-876-8600 Home

ADDRESS 310 TREEBARK RD STATESVILLE 28625

LOCATION 115N ⓒ PISGAH ⓛ TREEBARK Ⓡ HIDDEN RIVER 7TH LOT ON Ⓡ @ #170

SUBDIVISION HIDDEN RIVER BLOCK / SECTION LOT 7 LOT AREA 4.49 SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .25 GPD/FT²

Septic Tank: 1000 Gallons; STB 1007 Date 2-24-04
Pump Tank: 1000 Gallons; PT 274 Date 10-20-03
Pump Make: ZOELLER Model BN266-B Serial No. 266-0005
Nitrification Field: No Fields 1 Square Feet 1440 Linear Feet 360
No Lines 7 Trench Width 36" Max Trench Bottom Depth 24"

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI
System Description: PUMP 25% REDUCTION
Repair System Description: PUMP 25% RED.
Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 3
☐ Mobile Home No. Bathrooms 2.5
☐ Business No. Employees
☐ Other

Gravel Depth N/A ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing


Water Supply: ☑ Individual ☐ Public ☐ Community WELL


Comments:/Conditions: ① KEEP SEPTIC SYSTEM 100 FT FROM WELL, 15 FT FROM POOL, 50 FT FROM CREEK ② FILL AND PACK WASHOUT AREA ③ MAX DEPTH IS 24" ④ CONTRACTOR AND HEALTH DEPT RECOMMEND DRIVE PUT IN AFTER SEPTIC LINES TO MAINTAIN SETBACKS ⑤ SEE ATTACHED SKETCH SHEET FOR DRAINLINE DESCRIPTION.

Comments:/Conditions:

✱ CALL PRIOR TO INSTALLATION FOR CONSULTATIVE VISIT

INITIAL SITE SKETCH





HIDDEN RIVER RD.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit -- not to exceed sixty months.

Signed: _____ date 3-17-04 Installed by: Bill Deane

Improvement Permit by: Christopher M. Shemwell, RS date 3-16-04 Operation Permit by: Christopher M. Shemwell, RS date 5-7-04

Authorization to Construct by: Christopher M. Shemwell, RS date 3-16-04 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

DRAIN LINE DESCRIPTION

