HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 14K-2-A-9 & 10
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: ROGER & VICI GOFORTH OWNER: ✓ AGENT: PHONE: 873-7202 / 876-4727
ADDRESS: RT. 2, BOX 192 A APPLICATION DATE: 7/19/94 DATE EVALUATED: 7/19/94 ~
HIDDENITE, NC PROPOSED FACILITY: 3 BR HOUSE
28636 PROPERTY SIZE: AMPLE
LOCATION OF SITE: PISGAH RIDGE CIRCLE
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	R 0-2	0-24	C	ABK	1:1 / FI	.1942 WETNESS CONDITION S
		24-48	SC	WSBK	1:1 / FR	.1943/.1956 SAPROLITE PS
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.33
2	R 0-2	0-20	C	ABK	1:1 / FI	.1942 WETNESS CONDITION S
		20-48	SC	WSBK	1:1 / FR	.1943/.1956 SAPROLITE PS
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.33
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: KITTEN GOFORTH
COMMENTS:

DRAFT