DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Ron Halverson
ADDRESS: _____
PROPOSED FACILITY: USA Home
PROPOSED DESIGN FLOW (.1949): 480 gpd
LOCATION OF SITE: _____

APPLICATION DATE _____
DATE EVALUATED: 17 Jan 07
PROPERTY SIZE: 13 Ac.
PROPERTY RECORDED: _____

WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L / SL / 3%	0-9	wssk / scl	fr / ss sp	>48	>48	-	-	PS 0.3
		9-36	ssk / sc	fi / ss sp					
		36-48+	wssk / sc scp	fr / ss sp					
2	L / 5%	0-10	s / L	vfr / ss sp	>48	>48	-	-	PS 0.3
		10-48+	ssk / c	fi / ss sp					
3	L / 5%	0-9	sl / L	vfr / ss sp	>48	>48	-	-	PS 0.3
		9-48+	ssk / c	fi / ss sp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	TT	TT
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: TCH
OTHER(S) PRESENT: _____

COMMENTS: _____