IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

PART of

12365 OWNER OR CONTRACTOR JAMES MENSCER DATE 2/27/91 PERMIT NO. 14E-A-89

PHONE: Business _____ Home _____

LOCATION NC 115 N, TL PISGAH, TR BOWLES FARM, BEHIND 1ST DBL-WIDE ON (R) PAST HILL FARM RD S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms	3	No. Bathrooms	1 1/2	Character & Porosity of Soil	PS
Garbage Disposal Unit	Yes ( )		No (✓)	Percolation Rate	.4 GPD / FT2
Auto. Dishwasher	Yes (✓)		No ( )	Topography	6-10% LS
Auto. Wash. Machine	Yes (✓)		No ( )	Depth to Water Table	24'
Site Suitable	Yes (✓)		No ( )	Rock or other impervious formations	NONE

Lot Area .828 AC


TP 12/5/90

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓ WELL)
Public ( )



Plot of System

Installed by KENNY PEARSON

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 2/27/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold