IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Herbert Hatfield DATE May 19, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N. to Central, T.L. on 1561, go 2 miles, mobile home in field on left (behind brick house S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay Loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	good
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 8 slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unk
			Rock or other impervious formations	none observed

Lot Area 2.58 acres



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Bussey DATE 5/19/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold