IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Herbert W. Springer DATE 4-12-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N Cross Smew Creek – TL on SR 1572 – TL on SR 1573 Cross Creek (on left) S. R. No. 1573

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area Adequate

Character & Porosity of Soil Clay-Loyd Sandy Loam
Percolation Rate _____
Topography 4-6% slope
Depth to Water Table Deep
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Lee Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: Shed should be guttered – Mr. Springer agreed to do this.

CERTIFICATE OF COMPLETION BY Steven L. Poe DATE 4/12/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold