IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Norris Fox DATE 9 Oct 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 N. to Rd # 1561 - Scotts Central Rd. T.L. on Rd 1573 after crossing creek - 1st house on left. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	one
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to road.
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	ok
			Rock or other impervious formations	ok

Lot Area acreage



Plot of System Rd 1573

Size of Tank 1000 Gals

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Charlie Looney

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY W M Howard DATE 9 Oct 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold