DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dale Robinson
ADDRESS: 4096 Wilkesboro Hwy
PROPOSED FACILITY: 3BR
PROPOSED DESIGN FLOW (.1949): 360
LOCATION OF SITE: 4096 Wilkesboro Hwy
WATER SUPPLY: • Private • Public • Well • Spring • Other
EVALUATION METHOD: • Auger Boring • Pit • Cut
TYPE OF WASTEWATER: • Sewage • Industrial Process • Mixed

APPLICATION DATE 3/28/12
DATE EVALUATED: 5-2-12
PROPERTY SIZE: 1.27 Ac.
PROPERTY RECORDED: yes

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LS 18	0-19	C SBK	SS SP	Chr. 4 @ 40 n/a	48	n/a	n/a	.25 PS
		19-48	CL SBK	SS SP					
2	LS 18	0-21	C SBK	SS SP	Chr. 5 @ n/a 40"	48	n/a	n/a	.25 PS
		21-48	CL SBK	SS SP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	[illegible]	PS
System Type(s)	[illegible]	III
Site LTAR	[illegible]	.25

OTHER FACTORS (.1946): none
SITE CLASSIFICATION (.1948): [illegible] PS
EVALUATED BY: James Stewart
OTHER(S) PRESENT: Dale Robinson

COMMENTS: