HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Chris Davidson OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: St Johns Rd
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	linear 10%	0 to 6	L	GR		.1942 WETNES CONDITION - N/A
		6 to 30	C	ABK	1:1	.1943/ 1956 SAPROLITE - N/A
		30 to 48	C	weak ABK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
2	linear 10%	0 to 6	L	GR		1942 WETNES CONDITION - N/A
		6 to 32	C	ABK	1:1	1943/ 1956 SAPROLITE - N/A
		32 to 48	C	weak ABK	1:1	1944 RESTRICTIVE HORIZON - N/A
						1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3						1942 WETNESS CONDITION -
						1943/ 1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						1942 WETNESS CONDITION -
						1943/ 1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						1942 WETNESS CONDITION -
						1943/ 1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) Y/S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY: R-C-Moon OTHER(S) PRESENT: Neil Kale & Chris Davidson
COMMENTS:

DRAFT