IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

DATE 11/3/98

PERMIT# 074853 PIN# 4639734550 PT PHONE: Business 663-6905 Home

OWNER OR CONTRACTOR Crescent Resources

ADDRESS PO Box 1003 Charlotte NC 28201

LOCATION State Park Rd Wildlife Bay Rd Sierra Woods 6th lot on left after Deer Run

SUBDIVISION Wildlife Bay BLOCK / SECTION I LOT 74/74A LOT AREA SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 825 Date 3/8/00

Pump Tank: 100 Gallons; PT 300 Date 3/17/00

Pump Make: S Hydromatic Model SKHA 150M2 Serial No.

Nitrification Field: No Fields 1 Square Feet 1200' Linear Feet 400'

No Lines 4 at 100' Trench Width 36" Max Trench Bottom Depth 36"

[X] New System [ ] Repair System Type: I, II, III, IV, V, VI

System Description: Pump (PM) 25% Reduction

Repair System Description: Pump - Panel

Maintenance Agreement Required: [ ] Yes [X] No

Gravel Depth N/A [ ] Slab [ ] Crawl Space [X] Basement w/plumbing [ ] Basement wo/plumbing

[X] House/Mod. Home No. Bedrooms 4

[ ] Mobile Home No. Bathrooms 4

[ ] Business No. Employees


[ ] Other

Water Supply: [ ] Individual [ ] Public [X] Community


Comments:/Conditions: Keep Septic System at least 10' From PL & 50' From Lake.

Comments:/Conditions: 5-2 Top Two Lines installed on contour * corrected 50ft 2nd 70ft 3rd 80 last Two Lines 100 Bed
5-3 Last 3 Lines installed w/ Pressure manifold
5-4 Pressure Set Tanks inspected OK
5-7 Main Check - OK

Scale 1:100 INITIAL SITE SKETCH



AS'BUILT SKETCH



I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Paul G. Pinn (Fill this Area) date 11-9-98

Improvement Permit by: Mark H. Watson RS date 11/4/98

Authorization to Construct by: STEVE HODRICK date 10-22-99

Installed by: Lt W Gardner

Operation Permit by: C Bitter date May 9 2000

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD