IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

$315.00 Paid 876-2027 902-6704

PERMIT# 120401 PIN# 4720514396

OWNER OR CONTRACTOR KENT SHAW PHONE: Business 525-4421 Home DATE 5/12/04

ADDRESS PO BOX 1061 TROUTMAN NC 28166

LOCATION PERTH SOUTH - IR STATE PARK - IL WILDLIFE - TR SIERRA WOODS - IR MAPLE VIEW - AT END OF

SUBDIVISION WILDLIFE BAY BLOCK / SECTION # LOT 95 LOT AREA SITE CLASS PS DESIGN FLOW 360 PD L.T.A.R. .30 PD/FT2

Septic Tank: 1000 Gallons: STB 194 Date 12-14-04

Pump Tank: 1000 Gallons: PT 27 Date 12-12-04

Pump Make: MYERS Model MW50-11P Serial No. 2602D901

Nitrification Field: No Fields 1 Square Feet 410 Linear Feet 205

No Lines 3 Trench Width 24" Max Trench Bottom Depth 30" Gravel Depth N/A

☑ New System ☐ Repair System Type: I, II, III, (IV), V, VI

System Description: LP PANEL

Repair System Description: SAME

Maintenance Agreement Required: ☑ Yes ☐ No

☐ Slab ☐ Crawl Space ☑ Basement w/plumbing ☐ Basement wo/plumbing

☑ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 3

☐ Business No. Employees

☐ Other

Water Supply: ☐ Individual ☑ Public ☑ Community

Comments:/Conditions:

PT

ST

Comments:/Conditions: POLYLOK FILTER + RISER ON PT + MARKER ON ST

OWNER SAYS MOST [redacted] ARE BEYOND 50' SEPTIC

V'D JAMES 12-05

INITIAL SITE SKETCH 1"=40'

344'

CENTRAL VALVE BOX

GARAGE

87'

60'

70'

75'

REPAIR

112'

DRIVE

AS BUILT SKETCH

JACK MOORE, OPERATOR WAS ON JOB WHEN LINE 1 WAS INSTALLED. TUNDRA SEAL WAS NOT INSTALLED + ATTACHED FAR FROM TANK PANEL CONNECTION + STATES IN WRITING THAT IT IS NOT REQUIRED ON LOW PRESSURE SYSTEMS TO HAVE THE INNER SEAL.

V'D CONNECT

V'D LINES + TANK FROM CONTRACTOR 1-28-05

NEEDS ELECTRICAL + PRESSURE + OWNERS PERMISSION TO MOVE TANK

V'D ELECTRICAL + PRESSURE. EVERYTHING OK

OK TO MOVE TANKS

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 5/12/04

Improvement Permit by: _____ RS date 5/12/04

Authorization to Construct by: _____ RS date 5/12/04

Installed by: JAMES WOOLER

Operation Permit by: _____ RS date 3-14-05

Existing System Inspection by: _____ date

HEALTH DEPT COPY: WHITE