4720:56-9709

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Duke Power State Park DATE 6/27/79 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Toilet Building At Boat Launch Area.
182 Boat Launch Dr. - TMN 28166 S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )
Lot Area _____

Character & Porosity of Soil Prov Suitable
Percolation Rate 1" Per 60 min
Topography Steep Slope
Depth to Water Table Low
Rock or other impervious formations N



Plot of System

Size of Tank (2) 1500 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. _____ Linear Ft. 600
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public ( )

Installed by Bryant Stewart
Building Contractor

IMPROVEMENTS PERMIT BY _____

COMMENTS: 600' lineal feet of 2' T+J Panels. 18" Wide Trench. Backfilled with Sand. 1 foot of sand on bottom of trench beneath panels.

CERTIFICATE OF COMPLETION BY E. A. Stevenson Kellin W. Johnson R.S. DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold