IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas L. Nesbit Jr. DATE 12/4/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Smith Rd. at Troutman. T.R. on #1321 - T.R. on #1322 - T.R. in Sub Division - Log House on L. S. R. No. _____


SUBDIVISION NAME Cedarwood LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Prod Suitable
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes ( )	No ( )	Topography	Slight Slope Low
Site Suitable	Yes ( )	No ( )	Depth to Water Table	
			Rock or other impervious formations	None

Lot Area 1 acre



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Julian Bowles

IMPROVEMENTS PERMIT BY _____

COMMENTS: Divert surface water + water from house away from septic tank + line

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 12/4/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold