32744

09278.

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JOE NEAL FOX DATE 6-23-89 PERMIT NO. B17.

PHONE: Business Home

LOCATION Hicks Creek Rd. off East Monbo Rd. - new house on Ejnot Agee Const.

S.R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soils Gray Suitable.
Percolation Rate 2-10 Min. per in.
Topography 2-10%
Depth to Water Table 10+
Rock or other impervious formations None observed.

Lot Area 1 Acre.

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement




Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Lineal Ft. 300
Depth of Stone in Lines 12
Water Supply: Individual (✓)
Public ( )

Installed by Wes Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

Plot of System

IMPROVEMENTS PERMIT BY Paul Brown

COMMENTS

CERTIFICATE OF COMPLETION BY Wes Lytton DATE 6-23-89

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold