# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roy Jones DATE 5/19/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Out Buffalo Shoals Rd. T.L. at Rd 1333. Trailer on L. Last one on L. before fish lake S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 20,000 Sq ft +


Character & Porosity of Soil Cecil Clay

Percolation Rate _____

Topography Slope Low

Depth to Water Table _____

Rock or other impervious formations None




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 600 Linear Ft. 240

Depth of Stone in Lines 10" +

Water Supply: Individual (✓)

Public ( )

Installed by Sam Ostwalt

IMPROVEMENTS PERMIT BY _____

COMMENTS: Short 10' linear ft and 250 sq ft. Extra Stone used. This shortage was due to location of well and Property lines

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 5/19/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold