IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John C. Hicks DATE 7/12/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Out Buffalo Shoals Rd. to Rd 1333 - T.L. - T.R. on Rd #1429. Trailer on Rt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 100 X 150

Character & Porosity of Soil Prov. Suitable
Percolation Rate _____
Topography Slope Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 210
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank

IMPROVEMENTS PERMIT BY _____

COMMENTS: Existing Trailer taken off of another sewage system

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 7/12/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold