J.C. McNeely - Prot -

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Melvin Maasick DATE 11/4/75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 215, T.R. on Old Mt. Rd, T.L. on Troutman Historical Society Rd (#1334) go 1½ mile, on left S. R. No. 1334

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | |
| Auto. Dishwasher | Yes ( ) | No (✓) | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | |
| Site Suitable | Yes (✓) | No ( ) | |

Lot Area 7 acres


Character & Porosity of Soil Red Clay Loam

Percolation Rate more

Topography relatively level

Depth to Water Table Unknown

Rock or other impervious formations none observed




Plot of System

Size of Tank 1,250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. [illegible] Linear Ft. 300

Depth of Stone in Lines 10

Water Supply: Individual (✓)

Public ( )

Installed by Ryan Adams

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Cauyon DATE 11/26/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold