IREDELL COUNTY HEALTH DEPARTMENT

CJ

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 14456 PIN# 4721916705.001 6924 DATE 8-24-07

OWNER OR APPLICANT Percy Mills

ADDRESS PO Box 1315 Troutman NC 28166 PHONE: Business 704-928-5050 Home

LOCATION 21 South H (R) Oar (L) East Monbo (L) Hicks Creek (L) In Between Box #167 + Box #173

SUBDIVISION E. Leon Troutman, JR BLOCK / SECTION LOT 2 LOT AREA 1.109 SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 82 Date 9-11-07
Pump Tank: Gallons; PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet EC=1600' Linear Feet 400'
No Lines 3X133' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A ☒ Gravity ☐ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: Gravity 25% Reduction
Repair System Description: Low Pressure 50% Reduct
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 4 No. Persons 8 No. Employees
Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: (1) Install Lines on Contours & Maintain Setbacks (2) Keep Well 100' Away From Initial System. Space limitations are not encountered here.

Comments:/Conditions: (3) System & House Is completely Flagged OOT 9-14-07 New House Plan Submitted. Putting on 3 Bedroom & System is sized for 4 Bedroom. Polylok Filter & marker

INITIAL SITE SKETCH

AS BUILT SKETCH



Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Percy Mills date 8-24-07

Improvement Permit by: [signature] RS date 8/24/07

Authorization to Construct by: [signature] RS date 8/24/07

Installed by: Cherryville Grading

Operation Permit by: [signature] RS date 10-16-07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK