COPY

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 6884 DATE 8-21-97 TAX MAP NO. 4721976166 Watershed: ☐ Yes ☐ No

OWNER OR CONTRACTOR Albert Schneider PHONE: Business Home 873 9789

ADDRESS 324 Earlwood Rd Statesville, N.C.

LOCATION old mtn Rd to Eastmonbo TR Stonegate at end

SUBDIVISION BLOCK / SECTION LOT LOT AREA 73.57 acres SITE CLASS. OPS DESIGN FLOW 600 L.T.A.R. .13

Septic Tank: 1500 Gallons; STB 7997 Date 9-16-98
Pump Tank: Gallons; PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet 2000 Linear Feet 666
No Lines 5 Trench Width 36" Max Trench Bottom Depth 24" Gravel Depth

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI
System Description: Conv. Gravity Lay 450 gal
Repair System Description: Pump TO Conv. Lines
Maintenance Agreement Required: ☐ Yes ☑ No

☐ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 5 No. Bathrooms 4 No. Employees

☐ Slab ☐ Crawl Space ☑ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Community ☐ Public

Comments:
3 1 X 133'
3 1 X 33'
3 1 X 133'
Oak
Prop Lines
Trinity Oak
Room
5 Bedroom Main House Section
Garage
179'
Back out In Field Repair area

INITIAL SITE SKETCH

Comments:
locate well at least 100' from S.T. System or Repair area

AS BUILT SKETCH

Well is over 100' from S.T. 1-28-99
Stonegate
To Eastmonbo Rd

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed:

Improvement Permit by: R. C. Moore date 8-21-97
Authorization to Construct Existing System Inspection by: R. C. moore date 8-21-97

Installed by: WCS Lytton
Certificate of Completion by: date
Operation Permit by: R. C. moore date 1-28-99

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD

Authorization to Count Expires 60 mos from issue

Location of the proposed 20x50 Pool addition does not appear to impact the existing on-site septic system.**NOTE:

REHS

Date: 6-9-2011

ICHD-Environmental Health Division