IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy Wyatt DATE June 23, 1978 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd Past Kyles "X" Rd's, T. L. at graveyard across from Pleasant Hill Church go to private dirt Rd, next house in woods S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil Cecil Clay

Percolation Rate —


Topography slope to front

Depth to Water Table Low

Rock or other impervious formations none observed

Lot Area acreage

existing system



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Tom Outcalt

IMPROVEMENTS PERMIT BY _____

COMMENTS: System not surfacing at time of inspection. Mobile home must be moved off property prior to home being occupied. System originally inspected on 10/13/76

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 6/23/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold