00969

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR BRIAN SHAVER DATE 3-2-84 PERMIT NO.

PHONE: Business Home


LOCATION Buffalo Shoals Rd. - west 1/2 mi. past Kyles Xing on left. Enter st. into Timberlwek Dev. - 1st mobile home on left.

SUBDIVISION NAME A.F. TROUTMAN EST. LOT NO. 15 S. R. No. SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1-2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Pgvr. Suitable
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate 5 gal/sq. ft.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2 - 10%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 10+
Lot Area Ample			Rock or other impervious formations none observed.



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 720 Linear Ft 240

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Robert Hoke

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Surface water needs to be diverted around the S.T. system. Keep well at least 50' from S.T. system. Do not drive over drain lines.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 3-2-84

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold