DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: Land Dev. Services
ADDRESS: P.O. Box 5602 Statesville, NC APPLICATION DATE: 7-3-99 DATE EVALUATED: 8-12-99
PROPOSED FACILITY: 3 Bdrm House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .53
LOCATION OF SITE: Lot 12 Stonecheer Old NTR/Sth (R) Compt. Fork (R) SR 2707 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other Existing Well on Right
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	L/CC/R 0-2%	0-12	Plow						PS .3
		12-40	SBK C	FR SS/SP					
		40+	SBK C/Pl	FR					
2	L/CC/R 0-2%	0-12	Plow						PS .3
		12-36	SBK C	FR FM					
		36+	SBK C	FR FR					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	12"	Same
System Type(s)	25% Reduction	50% Reduction
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: J. Ketter
OTHER(S) PRESENT: _____