DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ___ APPLICANT: Land Development Service
ADDRESS: P.O. Box 5602 Statesville, NC APPLICATION DATE: 12-2-99 DATE EVALUATED: 1-20-2000
PROPOSED FACILITY: 3 Bdrm DW PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.66 Ac
LOCATION OF SITE: Lot 24 Stonecrest End of Compton Ak off Old Mt Rd PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 8-12%	0-33	SAB C	FR SS SP SEAP					PS 0.3
		33-52	SAB C w/ SAP inclusion	FR					
2	L 12-15%	0-6	SAB C CL	FR					PS 0.3
		6-48	SAB C	FR SS SP SEAP					
		48+	SAB C w/ SAP	FR					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	↘	
System Type(s)		
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [illegible] Sitton
OTHER(S) PRESENT: ___