09057

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR CURTIS MILLSAPS DATE 6-8-89 PERMIT NO. D 14

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd west-across 3/4 mi past Kyles Xing - Enter dr. on left - Lilac Blueberry Lane - Lot 31 at end. S. R. No. _____

SUBDIVISION NAME TIMBERBROOK DEV. LOT NO. 31 SECTION OR BLOCK NO. _____

House (+) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area 200' X 300'

Character & Porosity of Soil Fair Suitable

Percolation Rate 2 Hours 9 ft.

Topography 2 Hoyt 9 ft

Depth to Water Table 10 ft

Rock or other impervious formations none encountered

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (+)

Plot of System

Installed by Phil Rogers

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-5-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold