IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bill Holland DATE 6-26-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd To Old Mountain Rd T.L. TR on Rd 1441 House on R. Back off of Rd. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Iredell Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	40 Min Test
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight Slope Low
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	None

Lot Area 3 Acres



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 250 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Raymond Adams + Harry Reep

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6-26-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold